





100 CFM/1.5 Sones @ 0.10" SP., 87 CFM @ 0.25" SP., 30.5 Watts

Grill

Cold rolled steel, powder coated white.

Blower Wheel

One piece polymeric centrifugal blower wheel, 5.22" diameter, 2.90" wide, with 30 paddles.

Motor

Heavy duty, permanently split capacitor, 4 pole motor, life time lubrication, thermally protected. Rated 120 volts, 0.31 amps.

Contractor Pack (Motor/BladeGrill) Model: FAK100T*

Fan Housing

24 gauge galvanized steel housing, dimensions 10³/₄" x 9¹/₄" x 7⁷/₈". Contractor Pack Model: AKFH2*

Duct Collar

Metal collar for 4" duct connection, comes complete with built in back draft damper.


Ventilating Area

For rooms up to 125 sq. ft.

Unit Mounting

FRAK100 is centered between joists (with 16" centers) using hanging brackets. The housing will mount through drywall thickness up to $^{3}/^{4}$ ", with a rough-in opening of $10^{3}/^{4}$ " x $9^{1}/^{4}$ ".

* Sold in packs of 4. All three parts (housing, damper, motor/blade/grill) must be purchased and used together to make a complete unit.



Acceptable for use over tub or shower when installed in a GFCI protected branch circuit.





Damper

Blanket - Non-asbestos, ceramic blanket

Fusible Link - Replaceable, 165°F standard

Classification - CUL Listed 555C. California State Marshall classification for 1 hour fire damper rating. California State Marshall listing number 3225-1374-101.

Contractor Pack Model: AKFD2*

EXPANDED PERFORMANCE											
	Static Pressure (inches of w.g.)							Sones @ .1 SP	Sones @ .25 SP	Fan Speed RPM	Power Watts
	0	0.05	0.1	0.125	0.15	0.2	0.25				
Air Flow - CFM	108	104	100	99	97	93	87	1.5	1.5	1177	30.5

PROJECT							ARCHITECT				
LOCATION						ENGINEER					
CONTRACTOR	NTRACTOR						SUBMITTED BY DATE				
FAN MODEL Number Number	СҒМ	IN W.G.	RPM	WATTS	AMPS	SONES	QTY	OPTIONAL EQUIPMENT & REMARKS			



U.S.: 820 Lincoln Avenue West Chester, Pennsylvania 19380-4466 Tel: (610) 692-7400 • 877-304-3785 Fax: (610) 696-8048 Canada: 8 Edvac Drive Brampton, Ontario L6S 5P2 Tel: (905) 456-2033 Fax: (905) 456-1015