

## **Product Information**

| Applicable product:  |  |  |
|--|--|--|
| Elongated bowl toilet  | K-4321                                 |  |
| Fixture:   |  |  |
| Configuration  | Top spud, elongated                    |  |
| Water per flush  | 1.6 gal (6 L)*                         |  |
| Spud size  | 1-1/2"                                 |  |
| Passageway   | 2-1/8" (54 mm)                         |  |
| Water area   | 12-3/8" (314 mm) x<br>10-1/8" (257 mm) |  |
| Water depth from rim   | 4-1/4" (108 mm)                        |  |
| Seat post hole centers   | 5-1/2" (140 mm)                        |  |
| Minimum static pressure required   | 35 psi (241.3 kPa)                     |  |
| Maximum static pressure  | 80 psi (551.6 kPa)                     |  |
| Minimum flowing pressure required  | 25 psi (172.4 kPa)                     |  |
| Required supply minimum  | 25 gpm (94.6 lpm)                      |  |
| * Designed to flush with 1.6 gal (6 L) installed with a 1.6 gpf (6 lpf) valve. | of water when                          |  |

| Recommended accessories: |     |          |  |
|--------------------------|-----|----------|--|
| Floor bolts (pair)       |     | 21401    |  |
| Included components:     |     |          |  |
| Spud                     | 183 | 18357    |  |
| Seat                     | K-4 | K-4686-A |  |
| Bolt cap accessory pack  | 520 | 52048    |  |

## **Installation Notes**

Install this product according to the installation guide.

Refer to manufacturer and local codes for flush valve requirements.

Will comply with the American Disabilities Act (ADA) when installed per the requirements of the Accessibility Guidelines, Section 604 Water Closets, of the Act. The Model Plumbing Codes require the installation of elongated open-front toilet seats in public bathrooms.

Fixture conforms to ASME Standard A112.19.2/CSA B45.1. All dimensions are nominal.

