CAUTION – TO REDUCE RISK OF FIRE AND ELECTRICAL SHOCK

- Always turn off power at main switch prior to installation.
- System intended for installation by a qualified electrician, in accordance with NEC and local regulations.
- Consult with local inspector to assure compliance.
- For use with LED button lights only.


Model	LED-350MA03-RB
Input Voltage	120Vac,50/60Hz
Input Current	Max 0.2A
Output Current	350Ma
Each Port Output Voltage	2-12V DC
Each Port Load	3x1W LED Light
Each Port Load Lead Wires	12-22AWG
Output Port	1

FEATURES:

- 1. 350mA Constant Current for LED's optimized and stable performance.
- 2. Powers one LED Button lights
- 3. Special circuit design to protect LED from high voltage pulse.
- 4. Driver will automatically shut off if the fixtures are not properly wired. In this event, unplug and check the wiring and then plug it in again.

INSTALLATION:

- 1. Remove both covers.
- 2. Input wiring use only one knock out holes. Connect building wires to like color transformer wires with wire nuts.
- 3. Building ground wire may be green or un-insulated, and attaches to green wire from transformer box.
- 4. Output wiring Push down one set of the wiring terminals and insert fixture's red wire into the "+" terminal and the black wire into the "-" terminal.
- 5. Secure the covers by tightening the two screws.
- 6. The product should be installed on the either internal or external surface of any indoor construction.



WAC Lighting www.waclighting.com Phone (800) 526.2588 • Fax (800) 526.2585 Headquarters/Eastern Distribution Center 44 Harbor Park Drive • Port Washington, NY 11050 Phone (516) 515.5000 • Fax (516) 515.5050

CAUTION – TO REDUCE RISK OF FIRE AND ELECTRICAL SHOCK

- Always turn off power at main switch prior to installation.
- System intended for installation by a qualified electrician, in accordance with NEC and local regulations.
- Consult with local inspector to assure compliance.
- For use with LED button lights only.


Model	LED-350MA09-RB
Input Voltage	120Vac,50/60Hz
Input Current	Max 0.2A
Output Current	350Ma
Each Port Output Voltage	2-12V DC
Each Port Load	3x1W LED Light or 1-3 PCS LED
Each Port Load Lead Wires	12-22AWG
Output Port	3

FEATURES:

- 1. 350mA Constant Current for LED's optimized and stable performance.
- 2. Powers up to 3 LED Button lights
- 3. Special circuit design to protect LED from high voltage pulse.
- 4. Driver will automatically shut off if the fixtures are not properly wired. In this event, unplug and check the wiring and then plug it in again.

INSTALLATION:

- 1. Remove both covers.
- 2. Input wiring use only one knock out holes. Connect building wires to like color transformer wires with wire nuts.
- 3. Building ground wire may be green or un-insulated, and attaches to green wire from transformer box.
- 4. Output wiring Push down one set of the wiring terminals and insert fixture's red wire into the "+" terminal and the black wire into the "-" terminal.
- 5. Secure the covers by tightening the two screws.
- 6. The product should be installed on the either internal or external surface of any indoor construction.



WAC Lighting www.waclighting.com Phone (800) 526.2588 • Fax (800) 526.2585 Headquarters/Eastern Distribution Center 44 Harbor Park Drive • Port Washington, NY 11050 Phone (516) 515.5000 • Fax (516) 515.5050

LED-350MA12-RB

CAUTION - TO REDUCE RISK OF FIRE AND ELECTRICAL SHOCK

- Always turn off power at main switch prior to installation.
- System intended for installation by a qualified electrician, in accordance with NEC and local regulations.
- Consult with local inspector to assure compliance.
- For use with LED button lights only.


- ·	
Model	LED-350MA12-RB
Input Voltage	120Vac,50/60Hz
Input Current	Max 0.2A
Output Current	350Ma
Each Port Output Voltage	2-12V DC
Each Port Load	3x1W LED Light or 1-4 PCS LED
Each Port Load Lead Wires	12-22AWG
Output Port	4

FEATURES:

- 350mA Constant Current for LED's optimized and stable performance. 1.
- Powers up to 4 LED Button lights 2.
- Special circuit design to protect LED from high voltage pulse. 3.
- Driver will automatically shut off if the fixtures are not properly wired. In this event, unplug and check the wiring 4. and then plug it in again.

INSTALLATION:

- Remove both covers. 1.
- Input wiring use only one knock out holes. Connect building wires to like color transformer wires with wire nuts. 2.
- Building ground wire may be green or un-insulated, and attaches to green wire from transformer box. 3.
- 4. Output wiring - Push down one set of the wiring terminals and insert fixture's red wire into the "+" terminal and the black wire into the "-" terminal.
- After connecting all the LED fixtures, switch (S1-S4) should be at "ON" position for all terminals connected to a Button light. 5. Terminals not connected to a button light should be at "OFF" position.
- Secure the covers by tightening the two screws. 6.
- 7. The product should be installed on the either internal or external surface of any indoor construction.



WAC Lighting www.waclighting.com Phone (800) 526.2588 • Fax (800) 526.2585

Headquarters/Eastern Distribution Center 44 Harbor Park Drive • Port Washington, NY 11050 Phone (516) 515.5000 • Fax (516) 515.5050

Responsible Lighting®

CAUTION – TO REDUCE RISK OF FIRE AND ELECTRICAL SHOCK

- Always turn off power at main switch prior to installation.
- System intended for installation by a qualified electrician, in accordance with NEC and local regulations.
- Consult with local inspector to assure compliance.
- For use with LED button lights only.


Model	LED-350MA09-DIM-RB
Input Voltage	120Vac,50/60Hz
Input Current	Max 0.15A
Output Current	350mA
Each Port Output Voltage	2-12V DC
Each Port Load	3x1W LED Light or 1-3PCS LED
Each Port Load Lead Wires	12-22AWG
Output Port	3

FEATURES:

- 1. 350mA Constant Current for LED's optimized and stable performance.
- 2. Powers up to 3 LED Button lights
- 3. Special circuit design to protect LED from high voltage pulse.
- 4. Driver will automatically shut off if the fixtures are not properly wired. In this event, unplug and check the wiring and then plug it in again.

INSTALLATION:

- 1. Remove both covers.
- 2. Input wiring use only one knock out holes. Connect building wires to like color transformer wires with wire nuts.
- 3. Building ground wire may be green or un-insulated, and attaches to green wire from transformer box.
- 4. Output wiring Push down one set of the wiring terminals and insert fixture's red wire into the "+" terminal and the black wire into the "-" terminal.
- 5. Secure the covers by tightening the two screws.
- 6. The product should be installed on the either internal or external surface of any indoor construction.



WAC Lighting www.waclighting.com Phone (800) 526.2588 • Fax (800) 526.2585 Headquarters/Eastern Distribution Center 44 Harbor Park Drive • Port Washington, NY 11050 Phone (516) 515.5000 • Fax (516) 515.5050

Responsible Lighting®

CAUTION – TO REDUCE RISK OF FIRE AND ELECTRICAL SHOCK

- Always turn off power at main switch prior to installation.
- System intended for installation by a qualified electrician, in accordance with NEC and local regulations.
- Consult with local inspector to assure compliance.
- For use with LED button lights only.


Model	LED-350MA12-DIM-RB
Input Voltage	120Vac,50/60Hz
Input Current	Max 0.2A
Output Current	350mA
Each Port Output Voltage	2-12V DC
Each Port Load	3x1W LED Light or 1-4 PCS LED
Each Port Load Lead Wires	12-22AWG
Output Port	4

FEATURES:

- 1. 350mA Constant Current for LED's optimized and stable performance.
- 2. Powers up to 4 LED Button lights
- 3. Special circuit design to protect LED from high voltage pulse.
- 4. Driver will automatically shut off if the fixtures are not properly wired. In this event, unplug and check the wiring and then plug it in again.

INSTALLATION:

- 5. Remove both covers.
- 6. Input wiring use only one knock out holes. Connect building wires to like color transformer wires with wire nuts.
- 7. Building ground wire may be green or un-insulated, and attaches to green wire from transformer box.
- 8. Output wiring Push down one set of the wiring terminals and insert fixture's red wire into the "+" terminal and the black wire into the "-" terminal.
- 9. Secure the covers by tightening the two screws.
- 10. The product should be installed on the either internal or external surface of any indoor construction.



WAC Lighting www.waclighting.com Phone (800) 526.2588 • Fax (800) 526.2585 Headquarters/Eastern Distribution Center 44 Harbor Park Drive • Port Washington, NY 11050 Phone (516) 515.5000 • Fax (516) 515.5050