




SPECIFICATIONS
ASF70
EXHAUST FANS

**70 CFM/4.0 SONES @ 0.10" WG. -HVI CERTIFIED
120 Volts, 1.6 amps, 60 hz.**

• Grill

White polymeric grill secured in place via screw mounting through the light housing, dimensions - 10¹⁵/₁₆" x 10⁷/₁₆".



• Light Lens

High impact polycarbonate lens, secured in position using integral tabs; easily removed if necessary.

• Light Housing

Heavy gauge cold rolled steel c/w baked enamel finish; locks in place on the grill via two integral tabs.

• Blower Wheel

One piece polymeric wheel, 4¹/₂" diameter, 1" wide, with 10 fins.

• Motor

Single coil plug-in, two pole motor, life time lubrication, thermally protected. Rated 120 volts, 60 hz., 1.6 amps.

• Fan Housing

23 ga. Galvanized metal housing, dimensions 8" x 6⁷/₈" x 5¹/₂", double metal thickness mounting tabs.

• Duct Collar

Plastic collar for 4" duct connection, comes complete with built in non-metallic back draft damper for quiet operation.

• Lighting

Electronic Quick Start Ballast – rated 26 Watt – Use Triple 4 pin PL lamp. Maximum 26 Watt.

CUL/HVI

Acceptable for use over tub or shower when installed in a GFCI protected branch circuit.

• Unit Mounting

Rated Type IC for ceilings insulated to R-40. Designed to mount in ceilings with at least 6" of clearance. The unit will mount directly to the joist with a rough in opening of 8³/₁₆" x 7¹/₁₆". The housing will mount through drywall thickness up to 3/4".

• Ventilating Area

For bathrooms up to 70 sq. ft. for other rooms up to 85 sq. ft.

• Single Pack Shipping Info

Box Dim Box Dim 11¹/₂" x 13¹/₄" x 9¹/₂"
UPC 0-8316227321-5

HVI PERFORMANCE

Static Pressure (inches of w.g.)	0	0.05	0.1	0.15	0.2	0.25	0.3	0.35	0.4
CFM	77	74	71	68	65	61	57	52	45
RPM	2300	2400	2450	2500	2550	2600	2650	2710	2840
WATTS	65	66	65	64	64	63	61	60	58

Air-King exhaust fans are tested by the Air Movement and Control Association (AMCA) in accordance with HVI test standard 916, (Air Flow Test Standard) and HVI test standard 915 (Procedure For Loudness Rating Of Residential Fan Products). The Performance results are certified and verified by the Home Ventilating Institute (HVI).

PROJECT				ARCHITECT					
LOCATION				ENGINEER					
CONTRACTOR				SUBMITTED BY		DATE			
FAN NUMBER	MODEL NUMBER	CFM	IN W.C.	RPM	WATTS	AMPS	SONES	QTY	OPTIONAL EQUIPMENT & REMARKS



U.S.: 820 Lincoln Drive
West Chester, Pennsylvania 19380-4466
Tel: (610) 692-7400 • 877-304-3785
Fax: (610) 696-8048

Canada: 110 Glidden Road
Brampton, Ontario L6T 2J3
Tel: (905) 456-2033
Fax: (905) 456-1015