


SPECIFICATION SHEET

MODEL 707 FAN/LIGHT



A powerful ventilating fan with the look of a solid-oak light fixture.

FEATURES

GRILLE:

- Self-adjusting grille conceals fan interior
- Attractive, solid-oak grille frame
- Built-in light diffusing lens accepts up to 100W bulb (bulb not included)

BLOWER:

- Plug-in, permanently lubricated motor
- Polymeric blower wheel

HOUSING:

- Rugged, 26-gage galvanized steel construction
- Sturdy key-holed mounting brackets for quick, accurate installation
- Tapered, polymeric duct fitting with built-in backdraft damper for easy, positive duct connection and no metallic clatter

NOTE: For installation in ceilings up to 12/12 pitch.

U.L. Listed for use in insulated ceilings (Type I.C.) Use supply wiring rated for at least 90° C

SPECIFICATIONS

VOLTS	AMPS*	CFM	SONES	DUCT
120	2.0	70	3.5	4" Round

*Total Connected Load



HVI-2100 CERTIFIED RATINGS comply with new testing technologies and procedures prescribed by the Home Ventilating Institute, for off-the-shelf products, as they are available to consumers. Product performance is rated at 0.1 in. static pressure, based on tests conducted in AMCA's state-of-the-art test laboratory. Sones are a measure of humanly-perceived loudness, based on laboratory measurements.

TYPICAL SPECIFICATION

Fan/Light unit shall be Broan Model 707.


Unit shall have galvanized steel housing with dual integral mounting brackets. It shall be ducted to a roof or wall cap.

Blower assembly shall be removable and have a permanently lubricated motor.

Grille frame to be solid oak and self-adjusting. Lamp to be 100 Watts maximum, incandescent.

Air delivery to be no less than 70 CFM and sound level no greater than 3.5 Sones. Air and sound ratings shall be certified by HVI.

Unit shall be U.L. Listed for use in insulated ceilings (Type I.C.)



Broan-NuTone LLC, 926 West State Street, Hartford, WI 53027 (1-800-637-1453)

REFERENCE	QTY.	REMARKS	Project	
			Location	
			Architect	
			Engineer	
			Contractor	
			Submitted By	Date