## Single and Mixing Surgeon Scrub-Up Valves





Date:

#### Specification: (example)

- Forged brass, self close foot pedal valve
- Polished chrome plated finish trim
- Indexed pedals
- Heavy duty rigid/swivel gooseneck spout

and ... with ... (add control required) with ... (add spout required) with ... (add outlet required)





#### **Engineer/Architect Approval**

Model Specified:

Approval:

®
US

DESCRIPTION Surgeon Scrub-up Valve	54T5 PRO	DUCT NO.		
Juigeon Scrop-op valve	3413			C — US
CONTROL		SPOUT	OU	TLET
v		<b>✓</b>		
0	Specify "0" When No S Required	Spout	Specify "0" When No Outlet Required	
1	]   1		1	
2	Wallmounte Rigid/Swive Gooseneck	el l	Vandal Resistant 1.5 gpm (5.7 L/min Laminar with Agion® Antimicrobial	
Double Wallmount Valve, Inlet & Outlet Stops	Deckmounte 3 Rigid/Swive Gooseneck		Vandal Resistant 1.5 gpm (5.7 L/min Flow Control Aerato	
Double Floormount Valve	4	å	Standard 1.5 gpm (5.7 L/min Flow Control Aerato	
5	5		5	
6	6		6	
7	7		Smooth End, Laminar Flow Contro in Base of Goosened 1.0 gpm (3.8 L/min	sk Spout
8	8		8	
9	9		9	

(1) Available **Optional Rigid/Swivel Spouts**. These spouts can ONLY be added to **SPOUT Option No.'s 2, or 3.** (2) This outlet can ONLY be added to **SPOUT Option No.'s 2, or 3.** Refer to www.specselect.com for individual models.

Note: Use this page front and back as a product submittal sheet.

Flow Rates are at 60 PSI.



#### **Approvals:**

- CSA certified
- Complies to ASME A112.18.1/CSA B125.1
- Foot Pedal Control No. 3 Indicates compliance to ICC/ANSI A117.1
- Outlet options 2, 3, 4 and 7 are EPA WaterSense listed
- Verified compliant with 0.25% weighted average Pb content regulations

(Contact Delta Representative for State and/or Local Approvals.)

#### FLOW RATE vs PRESSURE FLOW FLOW (L/min.) (GPM) 2.5 9 8 2 7 6 5 3 30 40 50 70 80 Line Pressure (psig) **Spout Outlets** No. 3 & 4 Aerator No. 2 Laminar Flow Outlet ■■ No. 7 Flow Control

Note: It is strongly recommended that each supply line be equipped with a water hammer arrestor installed per manufacturer's instructions.

#### □ 060327A

1/2" NPT Water Hammer Arrestor

OUTLET	11	"D"	
NO.	mm	in.	
2	18	0.69	
3	18	0.69	
1	17	0.67	


### FOR OPTIONAL RIGID/SWIVEL SPOUTS


See DSP-R/S for detailed specification

Note: Measurements may vary ± 6mm (0.25")

## TECK® COMMERCIAL

# Single and Mixing Surgeon Scrub-Up Valves





Refer to www.specselect.com for individual models.

Note: Use this page front and back as a product submittal sheet.