


NOTES:

1. METRIC DIMENSIONS ARE IN BRACKETS [X].
2. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY EYEWASH OR EYEFACE WASH:
 - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
 - EYEWASH OR EYEFACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THEN 83.8 CM (33 IN.) AND NO GREATER THAN 114.3 CM (45 IN.) FROM SURFACE ON WHICH USER STANDS AND 13.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.
3. DIMENSIONS MAY VARY BY ± 1/2 [13].



1455 KLEPPE LANE
SPARKS, NEVADA 89431
(775) 359-4712 FAX (775) 359-7424
E-MAIL: HAWS@HAWS.CO.COM
WEBSITE: WWW.HAWS.CO.COM

DESIGN: 4161	REVISION: ECR 4367	DATE: 5-1-08	MODEL(S): 7260BT/7270BT	DATE: 5-1-08	INFO FAX DOC #: 272602 2726028 272702 2727028	DATE: 5-1-08	GRADING TYPE: INSTALLATION/REPAIR/REWORK	DATE: 5-1-08	SIZE: A	SHEET: 1 OF 1
--------------	--------------------	--------------	-------------------------	--------------	---	--------------	--	--------------	---------	---------------