



- NOTES:
1. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY EYEWASH OR EYEFACE WASH AND SHOWER EQUIPMENT:
    - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
    - EYEWASH OR EYEFACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THAN 83.8 CM (33 IN.) AND NO GREATER THAN 114.3 CM (45 IN.) FROM SURFACE ON WHICH USER STANDS AND 15.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.
  2. DIMENSIONS MAY VARY ±1/2" [12.7mm].

		<b>Haws®</b>	
1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 EMAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWSCO.COM		PART NUMBER 0002080068.D DRAWING NO.: 09450A00 1 8	
EQN NO: REVISED PER BY: MODEL(S)	ECON: 4472 HM 7324	EYEFACE WASH	
DRAWN: DATE: 05/21	CHKD: DATE:	SCALE: 1:1 DRAWING TYPE: INSTALLATION	
APPROVED: DATE:		SIZE: A SHEET: 1 OF 1	