



NOTES:

1. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY EYEWASH OR EYE/FACE WASH AND SHOWER EQUIPMENT:
 - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
 - EYEWASH OR EYE/FACE WASH SHALL BE POSITIONED WITH NOZZLES NOT LESS THEN 83.8 CM (33 IN.) AND NO GREATER THAN 114.3 CM (45 IN.) FROM SURFACE ON WHICH USER STANDS AND 15.3 CM (6 IN.) MINIMUM FROM WALL OR NEAREST OBSTRUCTION.

2. DIMENSIONS MAY VARY ±1/2" [12.7mm].

[3] MOUNTING HARDWARE SUPPLIED BY OTHERS.

[4] DIM APPLIES WHEN OPTIONAL 9102 DUST COVER ASSEMBLY IS USED.

		1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 E-MAIL: HAWS@HAWSO.COM WEBSITE: WWW.HAWSO.COM	
		ECN NO. REVISED PER BY: ECN: 5133 CJC DRAWN: DATE: CHK'D: C.J.L. 09/91 VWC APPROVED: DATE: FV 09/01/16	MODEL(S) 7778B EYE/FACE WASH
SCALE: 1/7		DRAWING TYPE: INSTALLATION	SIZE: A SHEET 1 OF 1