




SEE SHEET 2 OF 2 FOR TOP VIEW


**NOTES:**

1. TO COMPLY WITH ANSI Z358.1-2009 FOR EMERGENCY SHOWER EQUIPMENT:
  - UNIT SHALL BE INSTALLED IN ACCORDANCE WITH MANUFACTURER'S INSTRUCTIONS AND ACCEPTABLE PLUMBING PRACTICES.
  - SHOWER SHALL BE POSITIONED SO THAT SHOWER HEAD IS NOT LESS THAN 208.3 CM (82 IN.) NO MORE THAN 243.8 CM (96 IN.) FROM SURFACE ON WHICH USER STANDS.
  - SHOWER SPRAY PATTERN SHALL HAVE A MINIMUM DIAMETER OF 50.8 CM (20 IN.) AT 152.4 CM (60 IN.) ABOVE SURFACE ON WHICH USER STANDS, AND CENTER OF SPRAY PATTERN SHALL BE LOCATED AT LEAST 40.6 CM (16 IN.) FROM ANY OBSTRUCTION.
2. DIMENSIONS MAY VARY ±1/2" [12.7mm].


				1455 KLEPPE LANE SPARKS, NEVADA 89431 (775) 359-4712 FAX (775) 359-7424 EMAIL: HAWS@HAWS.CO.COM WEBSITE: WWW.HAWS.CO.COM	
EQN NO. REVISED PER BY:	MODEL(S)	SHOWER		PART NUMBER:	0002080137.D
DRAWN: ECK, JSD	DATE: 05/08	CHKD: 8163	SCALE: 1/16	DRAWING TYPE: INSTALLATION	SIZE: A
APPROVED:	DATE:				SHEET: 1 OF 2



TOP VIEW



ESCUTCHEON  
DETAIL A



1455 KLEPPE LANE  
SPARKS, NEVADA 89431  
(775) 359-4712 FAX (775) 359-7424  
EMAIL: HAWS@HAWS.CO.COM  
WEBSITE: WWW.HAWS.CO.COM

EQU NO. REVISED PERBY:	MODEL(S)	PART NUMBER:
DRAWN: ECK, 4/31	8163	0002080137.D
DATE: 4/31	CHKD:	DRAWING NO.: 13620A00
APPROVED: SHOWER	SCALE: 1/8"	REV: 17
	DRAWING TYPE: INSTALLATION	SIZE: A SHEET: 2 OF 2