



LIFTING HOLE VIEWS









NOTE: DIMENSIONS IN [ ] ARE ENGLISH EQUIVALENTS.

RESV

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL	BY
-	4-16-13	NEW DRAWING [CT106074]	GFR

UNLESS OTHERWISE SPECIFIED -
1) DIMENSIONS ARE IN MILLIMETERS
2) TOLERANCES ARE:
X.XX
X.X
X
ANGLES
SURFACE FINISH
MAX.
THIRD ANGLE PROJECTION

APPROVALS		DATE
DRAWN	GFR	4-16-13
CHECKED	BJF	4-16-13
APPROVED	BJF	4-16-13

KOHLER CO. METRIC PRO-E
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

TITLE
DIMENSION PRINT

SCALE 0.15 | CAD NO. | SHEET 1 of 3
DWG NO. ADV-8774 | D



VIEW FROM
INLET AIR OUTLET



VIEW FROM
EXHAUST AIR OUTLET

RESV

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL	BY
-	4-16-13	NEW DRAWING [CTI06074]	GFR

UNLESS OTHERWISE SPECIFIED -
1) DIMENSIONS ARE IN MILLIMETERS
2) TOLERANCES ARE:
X.XX
X.X
X
ANGLES
SURFACE FINISH
MAX.
THIRD ANGLE PROJECTION

APPROVALS		DATE
DRAWN	GFR	4-16-13
CHECKED	BJF	4-16-13
APPROVED	BJF	4-16-13

KOHLER CO. METRIC PRO-E
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

TITLE
DIMENSION PRINT

SCALE 0.20 | CAD NO. | SHEET 2 of 3
DWG NO. ADV-8774 | D







NOTE:
THE REQUIRED DISTANCE FROM A STRUCTURE IS DEPENDENT ON STATE AND LOCAL CODES. NFPA 37, STANDARDS FOR THE INSTALLATION AND USE OF STATIONARY COMBUSTION ENGINES AND GAS TURBINES.

ACCEPTABLE

1) EXHAUST IS AIMED AWAY OR PARALLEL TO STRUCTURE.
2) EXHAUST IS NOT DIRECTED AT PLAY AREAS, PATIOS OR OTHER AREAS WHERE PEOPLE CONGREGATE.
3) THE NEAREST WINDOW, VENT, DOOR OR SIMILAR STRUCTURE OPENING IS AT LEAST 5 FEET FROM THE EXHAUST END OF THE SET.
4) SET HAS PROPER OFFSET FROM STRUCTURE.
5) WINDOWS & DOORS ON ADJACENT WALLS ARE CLOSED.
6) FURNACE AND OTHER SIMILAR INTAKES ARE AT LEAST 10 FEET FROM EXHAUST END OF SET.
7) WEED BARRIER AND 3 INCH THICK GRAVEL BASE LOCATED TO PREVENT GRASS & WEEDS FROM GROWING TOO CLOSE TO THE SET.
8) NO PLANTS, SHRUBS OR OTHER COMBUSTIBLES ALLOWED IN GRAVEL AREA. (MINIMUM 4 FT. FROM EXHAUST END).
9) REFER TO OWNERS MANUAL FOR OTHER INSTALLATION CONSTRAINTS.
10) NO PLANTS, SHRUBS, OR OTHER COMBUSTIBLES ALLOWED WITHIN 18" OF AIR INTAKE.

RESV

REV	DATE	ON COMPOSITE DWGS, SEE PART NO. FOR REVISION LEVEL	BY
-	4-16-13	NEW DRAWING [CT106074]	GFR

UNLESS OTHERWISE SPECIFIED -
1) DIMENSIONS ARE IN MILLIMETERS
2) TOLERANCES ARE:
X.XX
X.X
X
ANGLES
SURFACE FINISH MAX.
THIRD ANGLE PROJECTION

APPROVALS		DATE
DRAWN	GFR	4-16-13
CHECKED	BJF	4-16-13
APPROVED	BJF	4-16-13

KOHLER CO. METRIC | PRO-E
POWER SYSTEMS, KOHLER, WI 53044 U.S.A.
THIS DRAWING IN DESIGN AND DETAIL IS KOHLER CO. PROPERTY AND MUST NOT BE USED EXCEPT IN CONNECTION WITH KOHLER CO. WORK. ALL RIGHTS OF DESIGN OR INVENTION ARE RESERVED.

TITLE
DIMENSION PRINT

SCALE 0.15 | CAD NO. | SHEET 3 of 3
DWG NO. **ADV-8774** | **D**