

Job Name/Location:

Tag #:

Date:

PO No.:

For:FileResubmitApprovalOther

Architect:GC:

Engr:Mech:

Rep:(Company)(Project Manager)

PQSH1202

Outdoor Unit Drain Pan Heater



Electrical:

Power Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Control Requirements	Wiring Harness Plugs into Outdoor Unit Control Board Terminal
Capacity (W)	120W

Compatibility:

9,000 and 12,000 Btu/h Single-Zone Cassette and Low Static Ducted Outdoor Units manufactured February 2018 and after.

- Notes:
1. Follow all installation instructions in the Base Pan Heater Installation manual.
 2. Ensure that there is at least 1-3/16" clearance from the outdoor unit fan.
 3. As a safety precaution, the heater will not energize if the outdoor temperature is higher than 32°F.
 4. To determine the date of the outdoor unit manufacture, refer to the first three digits of the serial number. First digit represents the year; second and third digits represent the month. For example, SN 503XXXXXX indicates date of manufacture of March 2015.
 5. Appearances may vary depending on model.

