

SCS Global Services does hereby certify that an independent assessment has been conducted on behalf of:

Mohawk Industries

508 East Morris Street, Dalton, GA, United States

For the following product(s):

Vinyl Tile:

Ballard 2.0, Westward 2.0, Ballard, Ballard 5.0, Ballard 6.0, Direct Import 3.5+1, Direct Import 4+1, Direct Import 5+1, Direct Import Program, Discovery Ridge, Explorers Cove, Everson, Founders Trace, Solidtech Better Program, Solidtech Better Small Program, Solidtech Good Program, Solidtech Opp Program, Westward, Westward 4.5, Westward 6.0

The product(s) meet(s) all of the necessary qualifications to be certified for the following claim(s):

FloorScore®

Indoor Air Quality Certified to SCS-EC10.3-2014 v4.0

Conforms to the CDPH/EHLB Standard Method v1.2-2017 (California Section 01350), effective April 1, 2017, for the school classroom and private office parameters when modeled as Flooring.

Measured Concentration of Total Volatile Organic Compounds (TVOC): Less than/equal to 0.5 mg/m³ (in compliance with CDPH/EHLB Standard Method v1.2-2017)

Registration # SCS-FS-07291

Valid from: August 27, 2021 to February 28, 2022

SCS Global Services is currently the only certification body approved by the Resilient Floor Covering Institute (RFCI) to provide FloorScore® product certification; certified products are only listed on the SCS Green Products Guide, <http://www.scsglobalservices.com/certified-green-products-guide>.



ANSI National Accreditation Board

ACCREDITED

ISO/IEC 17065

PRODUCT CERTIFICATION
BODY



A handwritten signature in black ink that reads "Stanley Mathuram".

Stanley Mathuram, PE, Executive Vice President
SCS Global Services
2000 Powell Street, Ste. 600, Emeryville, CA 94608 USA