

MFL - Filtration Box


In-line heavy-duty cabinet filters of type EU3 grade filtration are designed for direct connection with standard circular ducting.



The World's Leading Producer of
Air Movement Products
 6393 Powers Avenue
 Jacksonville, Florida 32217-2298
 P: 800.961.7370 F: 800.961.7379
 www.solerpalau-usa.com

Dimensions inches/mm

Type	A	B	D	E	F
MFL-100	$7 \frac{7}{8}$ 200	$7 \frac{7}{8}$ 200	$3 \frac{15}{16}$ 100	$6 \frac{1}{16}$ 154	$7 \frac{11}{16}$ 196
MFL-125	$7 \frac{7}{8}$ 200	$7 \frac{7}{8}$ 200	$4 \frac{15}{16}$ 125	$6 \frac{1}{16}$ 154	$7 \frac{11}{16}$ 196
MFL-150	$8 \frac{11}{16}$ 220	$8 \frac{11}{16}$ 220	$6 \frac{5}{16}$ 160	$6 \frac{1}{16}$ 154	$7 \frac{11}{16}$ 196
MFL-200	$9 \frac{9}{16}$ 243	$9 \frac{5}{8}$ 244	$7 \frac{7}{8}$ 200	$6 \frac{1}{16}$ 154	$7 \frac{15}{16}$ 202
MFL-250	$11 \frac{9}{16}$ 293	$11 \frac{7}{8}$ 294	$9 \frac{13}{16}$ 250	$6 \frac{1}{16}$ 154	$8 \frac{1}{8}$ 206
MFL-315	$13 \frac{7}{16}$ 342	$13 \frac{1}{2}$ 343	$12 \frac{3}{8}$ 315	$6 \frac{1}{16}$ 154	$8 \frac{1}{8}$ 206



ACCESSORY MODEL	1	2	3	4	5	REMARKS

PROJECT: _____ CONTRACTOR: _____
 LOCATION: _____ REVISION DATE: _____
 FORM NO.: _____ SUBMITTED BY: _____ DATE: _____
 ENGINEER: _____ APPROVED BY: _____ DATE: _____

For more information contact us at www.solerpalau-usa.com or 1.800.961.7370 for additional submittal drawings.

Soler & Palau will not be responsible for fabrication changes or errors resulting from customer use of a non-current submittal drawing.

