

T&S BRASS AND BRONZE WORKS, INC.

2 SADDLEBACK COVE / P.O. BOX 1088 / TRAVELERS REST, SC 29690

PHONE 800-476-4103

FAX 864-834-3518



REG.#A2601
ISO #9002

Model No.

B-CW-3/8


Item No.:

Job Name:

Architect/Engineer Approval:

Notes:

3/8" NPT FEMALE INLET



2 5/16"
[59mm]

3/8" NPT FEMALE OUTLET

NOTES:

1. MAXIMUM PRESSURE 400 PSI AT 200° F
2. NOT TO BE USED FOR NATURAL GAS APPLICATIONS.

Product Description:

VERTICAL CHECK VALVE FOR WATER USE ONLY
WITH 3/8" NPT INLET & OUTLET

Drawn:

WJS

Approved

MVW

Checked

ARY

Scale:

1' = 1'

Date:

8-13-97