White **▼**Rodgers



24A34-3

FEATURES

- Replaces Honeywell, MARS, TOD, GEMLINE, Klixon (Texas Instruments).
- 24V input control.
- · Multi-poise mounting.
- Any contacts (except M1 & M2) can be used as auxiliary contacts.
- Double quick-connect terminals for combination loads.

SPECIFICATIONS

ELECTRICAL RATINGS - SINGLE LOAD CONTACT RATINGS (ALL MODELS)

MODEL 24A34 ELECTRIC HEAT SEQUENCERSDirect Replacement for Most Fan/Heat Sequencing Functions.

Terminal Markings are Equivalent to Competitive Types

	Resistive (No	on-Inductive)	Motor Rating		
VAC	Watts	Amps	Full Load	Locked Rotor	Pilot Duty
120	3000	25.0	14.0A	72.0A	125 VA
240	6000	25.0	7.0A	42.0A	125 VA
480	6000	12.5	_	_	480 VA

Model				Timings – ON			Timings – OFF					
Number	Timings	Switches	M1-M2	M3-M4	M5-M6	M7-M8	M9-M10	M1-M2	M3-M4	M5-M6	M7-M8	M9-M10
24A34-1	1	1	1-20	_	_	_	_	40-110	-	_	ı	ı
24A34-2	1	1	_	_	30-90	_	_	_	_	1-30	_	_
24A34-3 ①	1	2	1-20 (1-20	_	-	_	40-110	40-110	_	-	_
24A34-4	1	2	_	_	30-90	30-90	_	_	_	1-30	1-30	ı
24A34-5 ①	2	3	1-110	1-110	1-110	_	_	1-110	1-110	1-110	-	_
24A34-6 ①	2	4	1-110	1-110	1-110	1-110	_	1-110	1-110	1-110	1-110	_
24A34-14①②	4	5	1-160	1-160	1-160	1-160	1-160	1-160	1-160	1-160	1-160	1-160
24A34-21	1	1	1-20	-	-	_	_	1-50	_	-	_	-
24A34-22	1	1	15-45	-	-	_	_	1-30	_	-	-	-
24A34-23	1	1	25-55	_	_	_	_	15-45	_	_	_	_
24A34-24	1	1	30-75	_	_	_	_	1-40	_	_	_	_
24A34-25	1	1	40-90	_	_	_	_	1-30	-	_	_	_
24A34-26	2	2	1-20	30-90	_	_	_	40-90	1-30	_	_	_
24A34-27	2	2	1-160	1-160	_	_	_	1-160	1-160	_	-	_
24A34-28 ③	2	2	1-160	1-160	-	_	_	1-160	1-160	-	_	_
24A34-29	1	1	15-35	-	-	_	_	25-55	_	-	_	_
24A34-36	2	2	1-20	30-45	_	_	_	45-110	1-30	_	_	_
24Δ34-37	1	1	1-110	_	_		_	1-110	_	_	_	_

COMBINED LOAD RATING TABLE (ALL MODELS)

30A @ 240 VAC - TOTAL,

23A Non-Inductive + 7 FLA/42 LRA Inductive, ON Time: Elapsed time to make contacts after

ON Time: Elapsed time to make contacts after heater is energized (min. to max.)

OFF Time: Elapsed time to break contacts after heater is de-energized (min. to max.)

TABLE NOTES:

- M1-M2 and M3-M4 are always first switches to turn ON and last to turn OFF. All other switches are random ON and random OFF
- 3 24A34-28 is 2 pole double throw
- ♦ These contacts switch simultaneously

NOTE: Underwriters Laboratories requires a fan interlock circuit to insure the blower remains operating whenever more than one sequencer is used. The fan interlock should be the M₁/M₂ contacts of the second or third sequencer.

All \dot{M}_1/\dot{M}_2 contacts are wired to the blower motor so that any sequencer that is energized will

24A34-15 HEAT PUMP CONTROL

FEATURES

- · Used in heat pump air handler applications.
- Provides a delay off to the blower motor in cooling mode.
- · Single pole double throw.

Model			Timings		
Number	Timings	Switches	ON 1-3	OFF 1-3	
24A34-15	1	1	1-60	75-95	

ELECTRICAL RATINGS - NORMALLY OPEN CONTACTS 1-3

	Resistive (No	on-Inductive)	Motor Ratings (Inductive)		
VAC	Watts	Amps	Full Load	Locked Rotor	Pilot Duty
120	3000	25.0	14.0A	72.0A	125 VA
240	6000	25.0	7.0A	42.0A	125 VA

ELECTRICAL RATINGS - NORMALLY CLOSED CONTACTS 1-2

	Resistive (No		
VAC	Watts	Amps	Pilot Duty
120	1200	10.0	125 VA
240	1200	5.0	125 VA